


No. 2012-BO-0186



Safety Certificate

KOSAPLUS Co., Ltd.

301-1Ho, 3Ba, 294, Gongdan2daero, Siheung, Gyeonggi, S.Korea

The following product produced by the above company has been authorized for the use of  the Mark as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

PRODUCT

LIMIT SWITCH BOX

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

ALS3*

CERTIFICATION No.

12-AV2B0-0186

CAPACITY · GRADE

Ex d IIC T6 IP67

Tamb: -20°C ~ +65°C

Refer to REAR for max ratings for Switch

SAFETY CERTIFICATION STANDARDS

Notification No. 2010-36 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

DATE : JUN. 10. 2013

MAR. 12. 2012(Original issue)

Signature H . K . Baek

President of Korea Occupational Safety and Health Agency

CERTIFICATION CONDITIONS

1.It is only for the product manufactured at "301-1Ho, 3Ba, 294, Gongdan2daero, Siheung, Gyeonggi, S.Korea"

2.Description

It is a flame-proof type limit switch box.

3.Maximum ratings for switches are as below.

Model	Switch ratings
ALS30	AC 16A-125V, 16A-250V
	DC 0.6A-125V, 0.3A-250V
ALS31	DC 0.1A-30V
ALS32	AC 16A-125V, 16A-250V
	DC 0.6A-125V, 0.3A-250V
ALS33	AC 5A-125V, 3A-250V
ALS34	AC 10A-125V, 10A-250V
	DC 0.5A-125V, 0.25A-250V

4.Conditions for safe use.

Tamb: -20℃ ~ +65℃

5.Certification (change) information

N/A

6.Other details

Comply with the duties such as managing quality control, surveillance and notifying any changes